



ITEM	PART #	MATERIAL	QTY
p		Connector, As Req'd	
av	3114	Jumper, #2 Insulated Tap	40
rp1	4766	Guard, 36" Perch	1
rp2	4764	Guard, 24" Perch	1
rp3	4762	Guard, 16" Perch	1
rp11	4721	Cover, Arrestero 2-Hole	3
rp12	4725	Cover, Cutout	3

ITEM	PART #	MATERIAL	QTY
rp13	4705	Cover, Small Transformer Bushing	3

- Notes:
1. Retrofit standard for avian and grouse protection for 8 ft. crossarms
 2. Bushing cover shall be installed over the first skirt of transformer bushing
 3. Call out additional transformer bushing covers as needed.

**24.9/14.4 kV, 3-Phase Transformer Bank
Avain/Grouse Retrofit
Without Cutouts**

RUS
3/2/2021
REV. B



**VG3MA-2
VG3MAG-2**