


- 1) All clearances and protective devices must be in conformance to the most stringent requirements of either the NESC, NEC, or other codes of governmental or regulating authorities as applicable.
- 2) Installation should be made by qualified electrician at service entrance.
- 3) All installations shall be inspected by PRECorp personnel prior to energizing.
- 4) Heat Rate meter must be clearly marked and have a path free of obstacles to the meter front.

**MATERIALS LISTING**

ITEM	DESCRIPTION	QTY	UNIT	PREC #
1	30A 6 Terminal Meter Base with Lever Bypass	1	Ea	
2	Form 3S Meter	1	Ea	

Design Parameters:  
 > See notes 1 through 4 above.

<b>Heat Rate Metering - Outside Installation</b> <b>Form 3S Meter on 6 Terminal Meter Base with Lever Bypass</b>		
Jan-07		<b>HEAT RATE SUB-METERING</b>
1 of 2		