



1. All clearances and protective devices to be in conformance to the most stringent requirements of either the NESC, NEC or other codes of governmental or regulating authorities as applicable.

MATERIALS LISTING

ITEM	DESCRIPTION	QTY	UNIT	PREC #
	Meter Pedestal, 100A Main	1		
	100A per position (UM8-3A)			
	Meter Pedestal, 200A Main	1		
	200A per position (UM8-3A)			
Ugv	Stake Support	1		
	Form 2S Class 200 240V 3-Wire 1Ø Meter	1		

Design Parameters:

>See design notes above

>4/0 USE-2 Cu (260A rating) or 2/0 URD Al Triplex (245A rating) recommended for secondary conductor

**Through Type Meter Pedestal (25kVA Transformer Max.)
120/240V 100A and 200A 3-Wire Meter Installations**

06/24/08
Rev. 0



UM8.3-02SC