



ITEM	QTY	MATERIAL	ITEM	QTY	MATERIAL
c	4	bolt, machine, 5/8" x req'd length	eb	2	Bracket, Pole top
d	3	washer, Square, 2 1/4"	ek	4	Locknuts
da	1	Bracket, insulated	rp6	1	Perch Guard Pole Top
ea	2	Insulator, Post type (24.9/14.4 kV)			

NOTES:

DESIGN PARAMETERS:

See TABLE IV

24.9/14.4 kV 1 PHASE
DOUBLE PRIMARY SUPPORT (TANGENT)
(POST INSULATORS)

RUS
03/04/08
Rev. 0

POWDER RIVER ENERGY CORPORATION

VA2.1PRG