


ITEM	MATERIAL	QTY	ITEM	MATERIAL	QTY
rp	cover up, salisbury	13'	a1	insulator, clamp type	2

NOTES:

1. Retrofit standard for avian protection for RUS configuration using an 8' crossarm.
2. This standard assumes a neutral spacing of >40" between center phase and neutral.
3. Two insulators need to be retired and replaced with clamp-type insulators.

**24.9 / 14.4 KV, 3-PHASE
SINGLE SUPPORT ON CROSSARM
(TANGENT)
AVIAN SAFETY RETROFIT**

RUS		VC1.11MA-1
10/1/10		
Rev. 0		