



ITEM	PART #	MATERIAL	QTY	ITEM	PART #	MATERIAL	QTY
a	4310	Insulator, Pin Type	2	az	0000	Decal For Neutral	
a2	4311	Insulator, Clamp Type	4	cm	9471	Insulator, Spool	2
c	9371	Bolt, Machine - 1/2"	4	cu	2040	Brace, Wood 84" X 24"	4
c2	9372	Bolt, Machine - 5/8"	3	da	2155	Clevis, Rigid	2
d	9098	Washer, Round 1/2"	4	ek	9094	Locknut, 1/2"	4
d2	9091	Washer, Square - 2" X 2"	4	ek	9096	Locknut, 5/8"	13
d3	9091-3-5/8	Washer, Square - 3" 11/16"	16	ek	9097	Locknut, 3/4"	2
d4	9091-4	Washer, Square - 4" 13/16"	2	rp	4715	Salisbury Coverup	16'
f	4375	Pin, Crossarm Saddle	6	rp1	4766	Perch Guard - 36"	2
g	4090	Crossarm, 10' Tangent	2	rp2	4764	Perch Guard - 24"	2
n	9363	Bolt, Double Arming, 5/8"	5	rp5	4780	Perch Guard - 30" Spikes	2
n2	9364	Bolt, Double Arming, 3/4"	1	rp7	4769	Perch Guard Extensions	6
aw	9100	Washer, Spring	8	rp8	4743	Perch Guard - Pole Top Cap	1

Design Parameters:

1. Maximum Line Angle: 2° for conductors larger than 1/0 ACSR.
2. For Line Angles larger than 2°, see RUS Bulletin 1728F-803 Table V. Replace items c2, d2, ek, cm, and da with a2 and f, and install item az.

Notes:

1. Coverup to extend 3' beyond crossarms.

**24.9/14.4KV,
3-PHASE DOUBLE PRIMARY SUPPORT,
CROSSARM CONSTRUCTION
LARGE CONDUCTORS**

RUS		VC2.51LRG
11/7/17		
REV. B		